

# VOC Content Test Certificate

Friday, 12<sup>th</sup> October 2017

Supplier: : Pasco Construction Solutions (15 Brighton St, Richmond VIC 3121).

Sample Description: Pasco Hypersil GP

Date Tested: September 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.1 13.1.1</b> <b>Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>Pasco Hypersil GP</b></p>
<p>General Purpose Adhesives and Sealants: 50 grams per Litre as VOC content per material</p>	<p><b>39 gram per Litre as VOC content per material</b></p>
<p><b><i>We hereby certify Pasco Hypersil GP is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV170865A**