

VOC Content Test Certificate

Tuesday October 20th, 2009

Distributor: Pasco Construction Solutions Pty Ltd. (13-15 Brighton Street Richmond VIC 3121)

Sample Description: Pasco Firecryl

Date Tested: October 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Pasco Firecryl
Architectural Sealant 250 grams per Litre as VOC content material	66 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Pasco Firecryl
Architectural Sealant 250 grams per Litre as VOC content material	66 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0910-08