



Professional Scientific Solutions

# VOC Content Test Certificate

Monday August 31<sup>st</sup>, 2009

Manufacturer: Pasco Construction Solutions (13 – 15 Brighton Road, Richmond Victoria 3121)

Sample Description: Pasco Hypercryl 363 Siliconised Acrylic Latex Sealant

Date Tested: August 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</b>	<b>Pasco Hypercryl 363</b>
Architectural sealant 250 grams per Litre as VOC content material	<b>129 grams per Litre as VOC content material</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Pasco Hypercryl 363</b>
Architectural sealant 250 grams per Litre as VOC content material	<b>129 grams per Litre as VOC content material</b>

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0908-28