



Professional Scientific Solutions

VOC Content Test Certificate

Monday August 31st, 2009

Manufacturer: Pasco Construction Solutions (13 – 15 Brighton Road, Richmond Victoria 3121)

Sample Description: Pasco Gap Sealant

Date Tested: August 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Pasco Gap Sealant
Architectural sealant 250 grams per Litre as VOC content material	66 grams per Litre as VOC content material
Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Pasco Gap Sealant
Architectural sealant 250 grams per Litre as VOC content material	66 grams per Litre as VOC content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0908-28