

VOC Content Test Certificate

Monday, 8th August 2022

Supplier: Pasco Construction Solutions Pty Ltd (241 Ingles Street, Port Melbourne, VIC, 3207, Australia).

Sample Description: Aquaproof 201 PU Ultra

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. The ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Aquaproof 201 PU Ultra
Water Proofing Membranes and Sealant Limit: 250 grams per litre	41 grams per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant

P22070136