

VOC Content Test Certificate

Wednesday 04th March 2020

Supplier: Bostik Australia Pty Ltd (Level 1, 6 English Street, Essendon Fields, Victoria, 3041, Australia).

Sample Description: Fireban Acrylic White FB 401

Date Tested: March 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as Referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Fireban Acrylic White FB 401
Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre	36 grams per Litre as VOC content per material
Specification Green Building Council of New Zealand Green Star Design & As Built NZ V1.0-13.1.1B Green Star Interiors NZ V1.0-12.1.1B	Fireban Acrylic White FB 401
Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre	36 grams per Litre as VOC content per material
<p><i>We hereby certify that Fireban Acrylic White FB 401 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia and Green Star Design, Green Building Council of New Zealand.</i></p>	



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Tuan Duong
 BE (Chem. Eng.)
 Consultant



Luke Morley
 BSc (Tech)
 Consultant

V2003001